

**ANNUAL DUST CONTROL REPORT
SUNFLOWER ELECTRIC POWER CORPORATION / HOLCOMB STATION
DECEMBER 9, 2021**

Introduction

Sunflower Electric Power Corporation / Holcomb Station has prepared this Annual Dust Control Report in accordance with 40 CFR 257.80(c) to document the following information for the Sunflower Electric Power Corporation / Holcomb Station Facility located near Holcomb, KS:

- Description of dust control procedures implemented at Holcomb Common Facilities, LLC.
- Summary of any concerns raised by stakeholders
- Description of any corrective actions taken

Implementation of Dust Control Procedures

During the last 12 months, dust control procedures have been implemented at Holcomb Common Facilities, LLC as discussed in the Dust Control Plan, dated October 15, 2015. A copy of the current Dust Control Plan is available on the Sunflower Electric Power Corporation / Holcomb Station internet site, as required by 40 CFR 257.105(g) and 257.107(g).

Stakeholder Correspondence

During the last 12 months, no concerns or complaints have been received by Sunflower Electric Power Corporation / Holcomb Station:

For each correspondence item, follow-up communication would be completed, and records would be maintained by Sunflower Electric Power Corporation / Holcomb Station. If needed, corrective actions will be implemented as discussed below.

Corrective Actions

Based on inspections and/or stakeholder correspondence during the last 12 months, no corrective actions have been identified to improve dust control at Sunflower Electric Power Corporation / Holcomb Station.

Closing

A copy of the most recent Annual Dust Control Report is available on the Sunflower Electric Power Corporation / Holcomb Station internet site, as required by 40 CFR 257.105(g) and 257.107(g). The Sunflower Electric Power Corporation / Holcomb Station internet site also provides contact information and requests that stakeholders contact Sunflower Electric Power Corporation / Holcomb Station with any concerns regarding dust controls at the Facility.

**HOLCOMB STATION
DUST CONTROL PLAN REVIEW DOCUMENTATION**

This Dust Control Plan has been reviewed in accordance with 40 CFR 257.80(b) to assess if more effective control procedures are available to significantly reduce the likelihood of CCR from becoming airborne at the facility.

By means of this certification, I attest that I have completed a review and evaluation of this Dust Control Plan for the Facility located near Holcomb, KS, and as a result

 Will

 X Will Not

amend the Dust Control Plan. Technical amendments to the Dust Control Plan will be certified by a Qualified Professional Engineer.

Emily Vsetecka
Signature, Authorized Facility Representative

12/09/21
Date

Emily Vsetecka

Name (Printed)

Manager, Environmental and Laboratory Services

Title